

Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

136

Annual Periodical Renewal Fire Certificate

From:
Regional Fire Officer
Andhra Pradesh, Vijayawada

To:
The District Educational Officer,,
Krishna District

File No: 1636/KRI/RFO/2018, Date:27/02/2018

Occupancy NoC RC Number: 74/RFO/ER/2015

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **RAVINDRA BHARATHI (E.M) SCHOOL, represented by V Venkateswara Rao, R.S.NO 240/3, KANURU, BANDAR ROAD, VIJAYAWADA** - Regarding.

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
 3. This Office NOC for Occupancy Rc No. 74/RFO/ER/2015, Dt.30/01/2015
 4. Renewal NOC For Occupancy 74/RFO/ER/2015, Dt.02/05/2017
 5. Online Application for Renewal NOC of V Venkateswara Rao, R.S.NO 240/3, KANURU, BANDAR ROAD, VIJAYAWADA - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 26/02/2018.

<< 0 >>

The Management of **RAVINDRA BHARATHI (E.M) SCHOOL**, represented by V Venkateswara Rao, R.S.NO 240/3, KANURU, BANDAR ROAD, VIJAYAWADA has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.9860/- vide challan No. 93445, Dated 29/01/2018 at State Bank of India, Governorpet.

ravindra bharathi (e.m) school

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **V Venkateswara Rao R.S.NO 240/3, KANURU, BANDAR ROAD, VIJAYAWADA**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

For Ravindra Bharathi Educational Academy

V Vamsi Kumar


Chairman

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 30/1/2018 to 29/1/2019.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.



1636/KRI/RF0/2018

Your Sincerely,

[Signature]
Regional Fire Officer
Andhra Pradesh, Vijayawada

Copy to V Venkateswara Rao, R.S.NO 240/3, KANURU, BANDAR ROAD, VIJAYAWADA

Copy to Chief Office for Record Purpose


Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

For Ravindra Bharathi Educational Academy

[Signature]
Chairman.



APTC FORM-10

GOVERNMENT OF ANDHRA PRADESH

Challan No: 31201437222019 Challan Creation Date & Time: 28/10/2019 11:39:09 AM
Treasury/PAO Code:0516 STO:STO-Vijayawada(West)
CFMS Transaction ID: 30100727072019
Major Head: 0070 Other Administrative Services
Sub-Major Head: 60 Other Services
Minor Head: 109 Fire Protection and Control
Group Sub-Head: 00 Not Applicable
Sub-Head: 81 Other Receipts
Detailed Head: 000 Not Applicable
Sub-Detailed Head: 000 NOT APPLICABLE
Charged/Voted: V
Non-Contingency/Contingency: N
Amount Rs: 20000.00
Amount In words Rs: Twenty thousand only

Purpose: RENEWAL OF FIRE NOC

Remitter's Name & Address: V VENKATESWARA RAO
RAVINDRA BHARATHI E.M.
SCHOOL,R.S.NO240/3,KANURU
VILLAGE,BANDAR ROAD,VIJAYAWADA

DDO Code: 05161005001
DVNL FIRE OFFICER VJA

Status: Payment Transaction Successful
Bank Reference Number: CHC1563938
Payment Date: 28/10/2019

Received Rs:.....20000.00.....

Note:This Challan does not need enfacement of the treasury

A.P. State Disaster Response and Fire Services Department

Acknowledgement for Periodic Renewal of Occupancy Certificate

Application Number	10162/KRI/RFO/2019	Building Name	RAVINDRA BHARATHI (E.M) SCHOOL
Site Address	R.S.NO 240/3, KANURU, BANDAR ROAD, VIJAYAWADA	District	Krishna
Address for Correspondence	RAVINDRA BHARATHI (E.M) SCHOOL, R.S.NO 240/3, KANURU, BANDAR ROAD, VIJAYAWADA	Licensing Authority	the District Educational Officer
Plot Area	0 Sq. Mtrs	Builder/Owner/Developer	K.Venkateswara Rao
Contact Number	08662550335	Mobile	9246497512
Email	rbps.acc@gmail.com	Applied On:	28-10-2019
Challan Number	31201437222019	Amount Paid	Rs. 20000/-
Date	28/10/2019	Bank / Branch	CFMS / Vijayawada



10162/KRI/RFO/2019